

Operator
Telephone
Fax
e-Mail

TONS DG-9921RL(ZHT-C29-24D) / UGR-Table

Luminaire: TONS DG-9921RL(ZHT-C29-24D)

Lamps: 1 x LUMINUS CXM-4-30-90-36-TE60-F7-2 150mA

Glare Evaluation According to UGR											
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	-0.3	0.4	-0.0	0.6	0.7	-0.3	0.4	-0.0	0.6	0.7
	3H	-0.4	0.2	-0.1	0.4	0.6	-0.4	0.2	-0.1	0.4	0.6
	4H	-0.5	0.1	-0.2	0.3	0.6	-0.5	0.1	-0.2	0.3	0.6
	6H	-0.5	-0.0	-0.2	0.2	0.5	-0.5	-0.0	-0.2	0.2	0.5
	8H	-0.6	-0.1	-0.3	0.2	0.5	-0.6	-0.1	-0.3	0.2	0.5
	12H	-0.6	-0.2	-0.3	0.1	0.4	-0.6	-0.2	-0.3	0.1	0.4
4H	2H	-0.5	0.1	-0.2	0.3	0.6	-0.5	0.1	-0.2	0.3	0.6
	3H	-0.6	-0.2	-0.3	0.1	0.4	-0.6	-0.2	-0.3	0.1	0.4
	4H	-0.7	-0.3	-0.3	0.0	0.4	-0.7	-0.3	-0.3	0.0	0.4
	6H	-0.8	-0.4	-0.4	-0.1	0.3	-0.8	-0.4	-0.4	-0.1	0.3
	8H	-0.8	-0.5	-0.4	-0.1	0.3	-0.8	-0.5	-0.4	-0.1	0.3
	12H	-0.8	-0.6	-0.4	-0.2	0.2	-0.8	-0.6	-0.4	-0.2	0.2
8H	4H	-0.8	-0.5	-0.4	-0.1	0.3	-0.8	-0.5	-0.4	-0.1	0.3
	6H	-0.9	-0.7	-0.4	-0.3	0.2	-0.9	-0.7	-0.4	-0.3	0.2
	8H	-0.9	-0.8	-0.5	-0.3	0.1	-0.9	-0.8	-0.5	-0.3	0.1
	12H	-1.0	-0.9	-0.5	-0.4	0.1	-1.0	-0.9	-0.5	-0.4	0.1
12H	4H	-0.8	-0.6	-0.4	-0.2	0.2	-0.8	-0.6	-0.4	-0.2	0.2
	6H	-0.9	-0.8	-0.5	-0.3	0.1	-0.9	-0.8	-0.5	-0.3	0.1
	8H	-1.0	-0.9	-0.5	-0.4	0.1	-1.0	-0.9	-0.5	-0.4	0.1
Variation of the observer position for the luminaire distances S											
S = 1.0H		+5.4 / -18.7					+5.4 / -18.7				
S = 1.5H		+8.2 / -28.4					+8.2 / -28.4				
S = 2.0H		+10.2 / -29.2					+10.2 / -29.2				
Standard table		BK00					BK00				
Correction Summand		-20.1					-20.1				
Corrected Glare Indices referring to 584lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.